

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING No. 1450-1100:101 Page 1 of 1

CATEGORY: Expansion Joints

LISTEE: MM Systems, 4520 Elmdale Dr., Tucker, GA 30084  
Contact: B Batten (706) 824-7586 \*Fax (706) 824-7501

DESIGN: Model THERMO-FLEX 2-hour fire-rated wall expansion joints, interior gypsum wallboard and metal stud wall type with FX-K-TFS-2h finish covers. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, detail number, hourly rating and CSFM label.

APPROVAL: Listed as a 2-hour fire-rated wall expansion joint with various finish cove

\*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**